

Translation

In any case, the german original shall prevail.

Fachausschuss Elektrotechnik Prüf- und Zertifizierungsstelle
Gustav-Heinemann-Ufer 130 50968 Köln

CentroSolar AG
Stresemannstraße 163
22769 Hamburg

Your ref.:
Your correspondence dated:
Our ref. UB.010.17/10-4450-2800
(please state): PIWi
Contact name: Wolfgang Pohl
Fax: +49 221 3778-6322
Date: 23.12.2010

Test Certificate 10066

Product: Automatic switching device (ENS)
Type: PGI ENS 2
Intended use: Automatic switching device, inaccessible to the distribution system operator, serving as a safety interface between a distributed generation system and the low-voltage grid. Equivalent substitute for a switching device with isolating function accessible at all times to the distribution system operator. This device is part of the PV-inverters:
Powerstocc 1200, 2000, 3000, 4000, 5000, 6000 Excellent

Testing performed in accordance with:

DIN V VDE V 0126-1-1: "Automatic disconnection device between a
2006-02 generator and the public low-voltage grid"

The safety concept of the product named above tested in the test report LB.010.00/03-2388 tested week 9/2004 and 20/2006, ref.: UB.010.17/10-4450-2800 satisfies the technical safety requirements in force at the time of issue of the present certificate for the normal use indicated.

The validity of the certificate of compliance shall cease no later than:

31 December 2013



- Martin Mehlem -
Head of the testing and certification body